



**LABOR RELATIONS DIVISION**

401 Broadway NE  
Albuquerque, NM 87102  
Phone: 505-841-4400  
Fax: 505-841-4424

226 South Alameda Blvd  
Las Cruces, NM 88005  
Phone: 575-524-6195  
Fax: 575-524-6194

[WWW.DWS.STATE.NM.US](http://WWW.DWS.STATE.NM.US)

**Wage Decision Approval Summary**

1) Project Title: Goddard High School Walk-In 2024-2631  
Requested Date: 03/15/2024  
Approved Date: 03/18/2024  
Approved Wage Decision Number: CH-24-0969-B

**Wage Decision Expiration Date for Bids: 07/16/2024**

2) Physical Location of Jobsite for Project:  
Job Site Address: 701 E Country Club Rd  
Job Site City: Roswell  
Job Site County: Chaves

3) Contracting Agency Name (Department or Bureau): Roswell Independent School District  
Contracting Agency Contact's Name: Mike Notz  
Contracting Agency Contact's Phone: (575) 627-2539 Ext.

4) Estimated Contract Award Date: 03/04/2024

5) Estimated total project cost: \$137,685.64  
a. Are any federal funds involved?: No  
b. Does this project involve a building?: Yes - Goddard High School Cafeteria  
c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No  
d. Are there any other Public Works Wage Decisions related to this project?: No  
e. What is the ultimate purpose or functional use of the construction once it is completed?: To provide new refrigeration for the Cafeteria

6) Classifications of Construction:

<b>Classification Type and Cost Total</b>	<b>Description</b>
<b>General Building (B)</b> <b>Cost: \$137,685.64</b>	Construction services to include constructing, renovating and remodeling buildings paid to contractors - Refrigeration equipment ( 3 systems) and the freezer and cooler boxes ( 2 boxes) All refrigerant lines, hanging hardware, copper condensate drain lines, a new floor sink will be installed and in cold room for all 3 systems to have a proper drain location ( Saw cut floor to tie in this new drain line to the existing drain in the cold room and replace removed concrete) J&G will be provided to disconnect power from the existing refrigeration equipment and boxes and reconnect to the new refrigeration equipment and boxes with 2 new convenience outlets