



LABOR RELATIONS DIVISION

401 Broadway NE
Albuquerque, NM 87102
Phone: 505-841-4400
Fax: 505-841-4424

226 South Alameda Blvd
Las Cruces, NM 88005
Phone: 575-524-6195
Fax: 575-524-6194

WWW.DWS.STATE.NM.US

1596 Pacheco St, Suite 103
Santa Fe, NM 87505
Phone: 505-827-6817
Fax: 505-827-9676

Wage Decision Approval Summary

1) Project Title: ASW 16-183M SWTP RWPS BP1 East Pump Rehabilitation
Requested Date: 02/23/2023
Approved Date: 02/24/2023
Approved Wage Decision Number: BE-23-0543-H

Wage Decision Expiration Date for Bids: 06/24/2023

2) Physical Location of Jobsite for Project:
Job Site Address: 6000 Alexander Blvd NE
Job Site City: Albuquerque
Job Site County: Bernalillo

3) Contracting Agency Name (Department or Bureau): Albuquerque Bernalillo County Water Utility Authority
Contracting Agency Contact's Name: Rochelle Larson
Contracting Agency Contact's Phone: (505) 289-3035 Ext.

4) Estimated Contract Award Date: 02/23/2023

5) Estimated total project cost: \$104,000.00
a. Are any federal funds involved?: No
b. Does this project involve a building?: No
c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No
d. Are there any other Public Works Wage Decisions related to this project?: No
e. What is the ultimate purpose or functional use of the construction once it is completed?: The Booster Pump 1 East at the Raw Water pump station is necessary to maintain design flow capacity for raw water delivery to the San Juan Chama Water Treatment Plant.

6) Classifications of Construction:

Classification Type and Cost Total	Description
Heavy Engineering (H) Cost: \$104,000.00	SJCWTP Plant Ops worked with Machine Dynamics, Inc. and carried out vibration testing which resulted in the recommendation to rebuild the pump. Teardown and inspection is required to determine if the pump requires repair or replacement. The pump rebuild/ replacement will bring the motor and pump into accordance with HI Standards and NEMA specification. This work consists of pulling inspecting, repairing/replacing and reinstalling the booster pump. Heavy equipment is needed to lift and transport the pump and motor.