



**LABOR RELATIONS DIVISION**

401 Broadway NE  
 Albuquerque, NM 87102  
 Phone: 505-841-4400  
 Fax: 505-841-4424

226 South Alameda Blvd  
 Las Cruces, NM 88005  
 Phone: 575-524-6195  
 Fax: 575-524-6194

**WWW.DWS.STATE.NM.US**

1596 Pacheco St, Suite 103  
 Santa Fe, NM 87505  
 Phone: 505-827-6817  
 Fax: 505-827-9676

**Wage Decision Approval Summary**

1) Project Title: Milan ES Fire Alarm Upgrade Level 1&2  
 Requested Date: 01/27/2022  
 Approved Date: 01/28/2022  
 Approved Wage Decision Number: CI-22-0257-B

**Wage Decision Expiration Date for Bids: 05/28/2022**

2) Physical Location of Jobsite for Project:  
 Job Site Address: 404 Sand Street  
 Job Site City: Milan  
 Job Site County: Cibola

3) Contracting Agency Name (Department or Bureau): Grants-Cibola County School  
 Contracting Agency Contact's Name: Vance Lee  
 Contracting Agency Contact's Phone: (505) 285-2600 Ext.

4) Estimated Contract Award Date: 12/10/2021

5) Estimated total project cost: \$175,514.24  
 a. Are any federal funds involved?: No  
 b. Does this project involve a building?: Yes - Milan Elementary School  
 c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No  
 d. Are there any other Public Works Wage Decisions related to this project?: No  
 e. What is the ultimate purpose or functional use of the construction once it is completed?: Fire Alarm Upgrade

6) Classifications of Construction:

<b>Classification Type and Cost Total</b>	<b>Description</b>
<b>General Building (B)</b> <b>Cost: \$175,514.24</b>	<ul style="list-style-type: none"> <li>- <input type="checkbox"/> To provide and install a complete and functional Hochiki/Firelite Voice EVAC fire alarm system per IBC &amp; IFC code requirements for specified occupancy type</li> <li>- <input checked="" type="checkbox"/> All Fire Alarm Design will comply with State Adopted Codes and PSFA Requirements for Existing Educational Facility</li> <li>- <input checked="" type="checkbox"/> All fire alarm cabling shall be FPLP rated cabling</li> <li>- <input checked="" type="checkbox"/> Fire alarm shop drawings stamped by NICET level III</li> <li>- <input checked="" type="checkbox"/> One year warranty will be provided on all material and labor</li> <li>- <input type="checkbox"/> To provide 1 year monitoring by 3rd Party UL Central Station, connected via owner provided POTS lines</li> <li>- <input type="checkbox"/> To provide As-Built Documentation upon completion</li> </ul>