



**LABOR RELATIONS DIVISION**

401 Broadway NE  
Albuquerque, NM 87102  
Phone: 505-841-4400  
Fax: 505-841-4424

226 South Alameda Blvd  
Las Cruces, NM 88005  
Phone: 575-524-6195  
Fax: 575-524-6194

[WWW.DWS.STATE.NM.US](http://WWW.DWS.STATE.NM.US)

**Wage Decision Approval Summary**

1) Project Title: Stormwater Pump Station Improvements  
Requested Date: 02/21/2024  
Approved Date: 02/22/2024  
Approved Wage Decision Number: DA-24-0666-H

**Wage Decision Expiration Date for Bids: 06/21/2024**

2) Physical Location of Jobsite for Project:  
Job Site Address: 101 Franklin Street  
Job Site City: Hatch  
Job Site County: Dona Ana

3) Contracting Agency Name (Department or Bureau): Village of Hatch  
Contracting Agency Contact's Name: Elizabeth Porras  
Contracting Agency Contact's Phone: (575) 267-5216 Ext.

4) Estimated Bid Opening Date: 12/14/2023

5) Estimated total project cost: \$901,298.50  
a. Are any federal funds involved?: Yes - \$782,000.00  
b. Does this project involve a building?: No  
c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No  
d. Are there any other Public Works Wage Decisions related to this project?: No  
e. What is the ultimate purpose or functional use of the construction once it is completed?: Pump station improvements.

6) Classifications of Construction:

Classification Type and Cost Total	Description
<b>Heavy Engineering (H)</b> <b>Cost: \$901,298.50</b>	Removal of existing MCC, conduit to wet well and pump cables, service conductors and service conduit, demolition of existing concrete slab, and installation of one new pump and new site electric and control elements to the existing storm water pump station. New pump installation including the removal of one existing 200 HP pump and replacement with 185 HP pump to include electrical connection and start up. New electric and control elements include but are not limited to a new multi-section MCC, new tri-plex pump control panel, conduit to wet well, site lighting, pin and sleeve receptacle for use with Owners existing generator, and reinforced concrete equipment pad.