



LABOR RELATIONS DIVISION

401 Broadway NE
 Albuquerque, NM 87102
 Phone: 505-841-4400
 Fax: 505-841-4424

226 South Alameda Blvd
 Las Cruces, NM 88005
 Phone: 575-524-6195
 Fax: 575-524-6194

WWW.DWS.STATE.NM.US

Wage Decision Approval Summary

1) Project Title: Power to Split Systems AC Units @ Chaparral MS - Lynco Electric - 232405206 MAF
 Requested Date: 03/25/2024
 Approved Date: 03/26/2024
 Approved Wage Decision Number: DA-24-1072-B

Wage Decision Expiration Date for Bids: 07/24/2024

2) Physical Location of Jobsite for Project:
 Job Site Address: 290 E Lisa Drive
 Job Site City: Chaparral
 Job Site County: Dona Ana

3) Contracting Agency Name (Department or Bureau): Gadsden Independent School District
 Contracting Agency Contact's Name: Dominique Esparza
 Contracting Agency Contact's Phone: (575) 882-6907 Ext.

4) Estimated Contract Award Date: 03/23/2024

5) Estimated total project cost: \$138,831.03
 a. Are any federal funds involved?: No
 b. Does this project involve a building?: Yes - Power to Split Systems AC Units @ Chaparral MS
 c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No
 d. Are there any other Public Works Wage Decisions related to this project?: No
 e. What is the ultimate purpose or functional use of the construction once it is completed?: Power to Split Systems AC Units @ Chaparral MS

6) Classifications of Construction:

Classification Type and Cost Total	Description
General Building (B) Cost: \$138,831.03	<ul style="list-style-type: none"> ☐ Disconnecting existing Evaporative cooling units from existing power source. ☐ Purchase and installation of new 30/2 Circuit Breakers for new Units (Some of these Circuit breakers may be refurbished due to lack of availability of new breakers for older panels, also some of the Breakers required have been purchased previously and will be supplied by owner) ☐ Pull out existing conductors to Evap. to make room for new# 10 conductors required for 2-ton units. ☐ Extend New Circuits to New Split System locations and make required connections. ☐ Purchase and install New 100-amp 3 pole 480v Circuit breaker for existing Panel H5 located in the 300-wing electrical room. (This Circuit Breaker may be refurbished due to the lack of New Circuit Breakers for this older panel)

- Install New 100-amp 480v Circuit from Panel H5 to new 75KVA transformer in Storage room in 400 wing corridor.
- Purchase and install 1 ea New 75KVA Dry type Transformer.
- Purchase and install 1 ea New 200-amp Panelboard in Storage room 400-wing corridor.
- Install new Branch Circuit feeds to New Split system Units in 400-wing from New Panel.
- New Mexico State Wage Scale Building B inside (Dona Ana County)
- % Bond