



LABOR RELATIONS DIVISION

401 Broadway NE
 Albuquerque, NM 87102
 Phone: 505-841-4400
 Fax: 505-841-4424

226 South Alameda Blvd
 Las Cruces, NM 88005
 Phone: 575-524-6195
 Fax: 575-524-6194

WWW.DWS.STATE.NM.US

1596 Pacheco St, Suite 103
 Santa Fe, NM 87505
 Phone: 505-827-6817
 Fax: 505-827-9676

Wage Decision Approval Summary

1) Project Title: Arrey Elementary School Digital Controls...Honeywell...ED...212201149
 Requested Date: 03/24/2022
 Approved Date: 03/25/2022
 Approved Wage Decision Number: SI-22-0811-B

Wage Decision Expiration Date for Bids: 07/23/2022

2) Physical Location of Jobsite for Project:
 Job Site Address: 4500 NM-187
 Job Site City: Arrey
 Job Site County: Sierra

3) Contracting Agency Name (Department or Bureau): Truth or Consequences Municipal Schools
 Contracting Agency Contact's Name: Sabrina Bierner
 Contracting Agency Contact's Phone: (575) 894-8160 Ext.

4) Estimated Contract Award Date: 03/02/2022

5) Estimated total project cost: \$131,403.45
 a. Are any federal funds involved?: No
 b. Does this project involve a building?: Yes - Arrey Elementary School
 c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No
 d. Are there any other Public Works Wage Decisions related to this project?: No
 e. What is the ultimate purpose or functional use of the construction once it is completed?: Forge Digital Control System Upgrade

6) Classifications of Construction:

| Classification Type and Cost Total | Description |
|--|--|
| General Building (B) Cost: \$131,403.45 | Furnish and install DDC CPO Controls and Forge enablement as an Extension to the Existing. Remove existing router panel/controller and install new communication router. Remove existing AC unit controllers, space temp sensors. Install new communication router. Install new CPO controller in place of existing and re-terminate existing to existing control wiring. Reuse all field wiring for 24vac Power, thermostat, unit controls, SAT and CT. Provide and install new BACnet communication cable for new communication controller to AC units Controllers |